



City of Sebastopol
7425 Bodega Ave., Sebastopol, CA 95472

RESIDENTIAL
2013 CALGreen+Tier 1 Checklist

(Based on CALGreen + Tier 1)

Applies to building permit applications received on or after January 1, 2014, for newly constructed hotels, motels, lodging houses, dwellings, dormitories, condominiums, shelters, congregate residences, employee housing, factory-built housing and other types of dwellings containing sleeping accommodations with or without common toilet or cooking facilities including accessory buildings, facilities and uses thereto. (Residential additions or alterations that increase conditioned space are subject to CALGreen. See separate checklist) Repairs to existing structures are not subject to CALGreen at this time.)

Project Address: _____

Project Name: _____

Project Description: _____

Instructions:

1. The Owner or the Owner's agent may employ a listed qualified Green Building Special Inspector to perform Green Building Special Inspector services and to verify and assure the Owner and the Building Division that all required work described herein is properly planned and implemented in the project.
2. The Green Building Special Inspector shall not be the design professional or contractor for the project and shall not have a financial interest in the project for which services are being provided except for the cost of providing said services.
3. The Green Building Special Inspector, in collaboration with the owner and the design professional, shall initially complete **Columns 1 and 2** of this checklist, sign and date the CALGreen Building Acknowledgements section at the end of this checklist and have the checklist printed on or attached to the approved plans for the project.
4. Prior to final inspection by the Building Division, CALGreen Building Special Inspector, except where verification by City is noted, shall complete **Column 3** and provide verification of completion prior to final inspection by City staff.

Column 1 Feature or Measure	Column 2 Project Requirements <i>When checked, these items become a part of the approved plans and must be installed or incorporated into the project.</i>	Column 3 Verification <i>Complete after installation & prior to final inspection approval</i>
See Chapter 4 and Appendix A4 of the 2013 California Green Building Code and the local jurisdiction for complete descriptions of features or measures listed here.	Mandatory & Tier 1 Prerequisites	Tier 1 electives <i>Applicant selects required elective measures</i>
		Verification by a 3rd party Special Inspector or by local jurisdiction staff as noted below

A4.1 PLANNING AND DESIGN	<i>All checked items are required for the project</i>	<i>Select at least two (2) elective measures from A4.1</i>	<i>Select all measures verified in the completed project</i>
Site Selection			

Feature or Measure	Required	Electives	Verification by
A4.103.1 Selection. A site which complies with at least one of the following characteristics is selected: (Support documentation required at application submittal) <ol style="list-style-type: none"> 1. An infill site is selected. 2. A greyfield site is selected. 3. An EPA-recognized and remediated Brownfield site is selected. 		<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	City Plan Check staff <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Site Preservation			
A4.104.1 Individuals with oversight authority on the project who have been trained in areas related to environmentally friendly development can teach green concepts to other members of the development staff and ensure that training is provided to all parties associated with the project. Prior to beginning the construction activities, all parties involved with the development process shall receive a written guideline and instruction specifying the green goals of the project.		<input type="checkbox"/>	Special Inspector <input type="checkbox"/>
Deconstruction and Reuse of Existing Materials			
A4.105.1 Existing buildings on the site are deconstructed and the salvaged materials (which must comply with current building standards) are reused. A4.105.2 Materials which can be easily reused include but are not limited to the following: <ol style="list-style-type: none"> 1. Light fixtures 2. Plumbing fixtures 3. Doors and trim 4. Masonry 5. Electrical devices 6. Appliances 7. Foundations or portions of foundations 		<input type="checkbox"/>	Special Inspector <input type="checkbox"/> Verify at least one <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Site Development			
4.106.2 Storm water drainage and retention during construction. Newly constructed projects which disturb less than one acre of land shall prevent the pollution of storm water runoff from the construction activities by complying with lawfully enacted storm water management and/or erosion control ordinances. See Sebastopol City Code Chapter 13 & 15.74	<input checked="" type="checkbox"/>		City Building Inspector <input type="checkbox"/>
<i>Description of proposed measures:</i>		<i>Sheet:</i>	<i>Detail:</i>

Feature or Measure	Required	Electives	Verification by
<p>A4.106.8 Electric vehicle (EV) charging. Dwellings shall comply with the following requirements for the future installation of electric vehicle supply equipment (EVSE)</p> <p>A4.106.8.1 One- and two-family dwellings. Install a listed continuous raceway (minimum size trade size 1", fastened at the main service or subpanel, terminating in close proximity to the proposed location of the charging system into a listed cabinet/box/enclosure) to accommodate a dedicated branch circuit.</p> <p>A4.106.8.1.1 Labeling requirement. A label stating "EV CAPABLE" shall be posted in a conspicuous place at the service panel or subpanel and next to the raceway termination point.</p> <p>A4.106.8.2 Multifamily dwellings. At least 3% of the total parking spaces, but not less than one, shall be capable of supporting future electric vehicle supply equipment (EVSE)</p> <p>A4.106.8.2.1 Single charging space required. When only a single charging space is required, install listed raceway per A4.106.6</p> <p>A4.106.8.2.2 Multiple charging spaces required. When multiple charging spaces are required, plans shall include the location(s) and type of the EVSE, raceway method(s), wiring schematics and electrical calculations to verify that the electrical system has sufficient capacity to simultaneously charge all the electrical vehicles at all designed EV charging spaces at their full rated amperage. Plan design shall be based upon Level 2 EVSE at its maximum operating ampacity. Only underground raceways and related underground equipment are required to be installed at the time of construction. (Support documentation required at application submittal)</p> <p>A4.106.8.2.3 Labeling requirement. A label stating "EV CAPABLE" shall be posted in a conspicuous place at the service panel or subpanel and next to the raceway termination point.</p>		<input type="checkbox"/> As applicable <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Special Inspector <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<i>Description of proposed measures:</i>	<i>Sheet: Detail:</i>		
<p>A4.106.9 Bicycle parking. Comply with Sections A4.106.9.1 through A4.106.9.3 or meet local ordinance, whichever is more stringent.</p> <p>Exception: Spaces may be reduced as approved by enforcing agency, due to building site characteristics, including but not limited to, isolation from other development.</p> <p>A4.106.9.1 Short-term bicycle parking. Provide permanently anchored bicycle racks within 100 ft. of the visitor's entrance for 5% of visitor motorized vehicle parking capacity with a minimum of one 2-bike capacity.</p> <p>A4.106.9.2 Long-term bicycle parking for multifamily buildings. Provide on-site conveniently reached bicycle parking facilities for at least one bicycle per every 2 dwelling units</p> <p>A4.106.9.3 Long-term bicycle parking for hotel and motel buildings. Provide one on-site conveniently reached bicycle parking facilities for every 25,000 sq. ft., but not less than 2.</p>		<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<i>Description of proposed measures:</i>	<i>Sheet: Detail:</i>		

Feature or Measure	Required	Electives	Verification by
<p>A4.106.10 Light pollution reduction. Outdoor lighting systems shall be designed and installed to comply with the following:</p> <ol style="list-style-type: none"> The minimum requirements in the California Energy Code for Lighting Zones 1-4 as defined in Chapter 10 of California Administrative Code; and Backlight, Uplight and Glare (BUG) ratings as defined in IES TM-15-11; and Allow BUG ratings not exceeding those shown in Table A4.106.10 <p>Exceptions:</p> <ol style="list-style-type: none"> Luminaires that qualify as exceptions in the California Energy Code, Emergency lighting One and two family dwellings 		<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<i>Description of proposed measures:</i>	<i>Sheet: Detail:</i>		
Innovative Concepts and Local Environmental Conditions			
<p>A4.107.1 Items in this section are necessary to address innovative concepts or local environmental conditions These items must be approved by the Building Department prior to listing here.</p>			Chief Building Official
Item 1:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<p>A4.2 ENERGY EFFICIENCY <i>All checked items are required</i> <i>Select all measures verified in the completed project</i></p>			
Performance Approach General			
<p>4.201 Energy Performance. Comply with minimum requirements of 2010 California Energy Code</p> <p>4.203.1 Install Solar Photovoltaic system. See Sebastopol City Code 15.72 for complete descriptions of features or measures listed here.</p>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	City Building Inspector <input type="checkbox"/>

Feature or Measure	Required	Electives	Verification by
<p>A4.303.3 Appliances. Dishwashers and clothes washers in residential buildings shall comply with the following:</p> <p>Install at least one qualified ENERGY STAR appliance with maximum water use as follows:</p> <ol style="list-style-type: none"> 1. Standard Dishwashers – 4.25 gallons per cycle. 2. Compact Dishwashers – 3.5 gallons per cycle 3. Clothes washers – water factor of 6 gallons per cubic feet of drum capacity. 		<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<p>A4.303.4 Nonwater supplied urinals and waterless toilets. Nonwater supplied urinals or composting toilets are installed.</p> <p>Note: Check with local jurisdiction on code requirements.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
<p>Outdoor Water Use</p> <p>See Sebastopol City Code Chapter 15.74, Water Efficient Landscape Ordinance</p>			<p>All Outdoor Water Use verified by City Water Efficient Landscape Ordinance Staff</p>
<p>4.304.1 Irrigation controllers. Automatic irrigation systems installed at the time of final inspection shall be weather-based or soil based with rain sensor.</p>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
<p>A4.304.1 Low-water consumption irrigation system. Install a low-water consumption irrigation system which minimizes the use of spray type heads. (See SRCC 14-30)</p>		<input type="checkbox"/>	<input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.304.2 Rainwater systems. A rainwater capture, storage and re-use system is designed and installed to use rainwater generated by at least 65% of the available roof area (per Cal Plumbing Code)</p>		<input type="checkbox"/>	<input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.304.3 Water budget. A water budget shall be developed for landscape irrigation per Santa Rosa City Code Chapter 14-30. (Support documentation required at application submittal)</p>		<input type="checkbox"/>	<input type="checkbox"/>
<p>A4.304.4 Potable water reduction. Reduce the use of potable water to a quantity that does not exceed 65% of ETo times the landscape area.(Tier 1) (Support documentation required at application submittal)</p> <p>Note: See Santa Rosa Water Efficient Landscape Ordinance.</p>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
<p>A4.304.5 Potable water elimination. A landscape design is installed which does not utilize potable water. (Support documentation required at application submittal)</p>		<input type="checkbox"/>	<input type="checkbox"/>
<p>A4.304.6 Irrigation metering device. For new water service connections, landscaped irrigated areas more than 2,500 sq. ft. shall be provided with separate submeters or metering devices for outdoor potable water use.</p>		<input type="checkbox"/>	<input type="checkbox"/>

Feature or Measure	Required	Electives	Verification by
WATER REUSE SYTEMS			
A4.305.1 Graywater. Alternate plumbing piping is installed to permit the discharge from the clothes washer or other fixtures to be used for an irrigation system in compliance with the California Plumbing Code.		<input type="checkbox"/>	<i>Special Inspector</i> <input type="checkbox"/>
A4.305.2 Recycled water piping. Based upon projected availability, dual water piping is installed for future use of recycled water at interior and exterior locations. Interior piping for use of recycled water for water closets, urinals and floor drains. Exterior piping to transport recycled water from the point of connection to the structure.		<input type="checkbox"/>	<i>Special Inspector</i> <input type="checkbox"/>
A4.305.3 Recycled water for landscape irrigation. Recycled water is used for landscape irrigation.		<input type="checkbox"/>	<i>Special Inspector</i> <input type="checkbox"/>
Innovative Concepts and Local Environmental Conditions			
A4.306.1 Innovative concepts and local environmental conditions. Items in this section are necessary to address innovative concepts or local environmental conditions. These items must be approved by the Building Division prior to listing here.			Chief Building Official
Item:		<input type="checkbox"/>	<input type="checkbox"/>

Feature or Measure	Required	Electives	Verification by
A4.4 MATERIAL CONSERVATION AND RESOURCE EFFICIENCY	<i>All checked items are required</i>	<i>Select at least two (2) elective measures from A4.4</i>	<i>Select all measures verified in the completed project</i>
Foundation Systems			
A404.3.2 Reduction in cement use. Cement use in foundation mix design is reduced by not less than a 20 percent. (Tier 1) Note: As allowed by the enforcing agency, any design cement mix must be authorized and approved by Architect of Record.	☒		City Building Inspector <input type="checkbox"/>
Efficient Framing Techniques			
A4.404.1 Lumber size. Beams and headers and trimmers are the minimum size to adequately support the load.		☐	<i>Special Inspector</i> <input type="checkbox"/>
A4.404.2 Building dimensions & layouts. Building dimensions and layouts are designed to minimize waste in at least 80% of the structure. <ol style="list-style-type: none"> 1. Building design dimensions in 2' increments 2. Windows & doors are located at regular 16" or 24" o.c. stud positions. 3. Other methods acceptable by enforcing agency. 		☐	<i>Special Inspector</i> <input type="checkbox"/>
A4.404.3 Building systems. Use pre-manufactured building systems to eliminate solid sawn lumber whenever possible.		☐	<i>Special Inspector</i> <input type="checkbox"/>
A4.404.4 Pre-cut materials and details. Material lists are included in the plans which specify material quantity and provide direction for on-site cuts. (Support documentation required at application submittal)		☐	<i>Special Inspector</i> <input type="checkbox"/>
Material Sources			
A4.405.1 Prefinished building materials. <u>One</u> or more of the following building materials, that do not require additional resources for finishing are used: <ol style="list-style-type: none"> 1. Exterior trim not requiring paint or stain. 2. Windows not requiring paint or stain. 3. Siding or exterior wall coverings which do not require paint or stain. 		☐	<i>Special Inspector</i> <input type="checkbox"/>

<p>A4.405.4 Use of building materials from rapidly renewable sources. One or more of the following materials manufactured from rapidly renewable sources or agricultural by-products is used.</p> <ol style="list-style-type: none"> 1. Insulation 2. Bamboo or cork 3. Engineer products 4. Agricultural based products. 5. Other products acceptable to enforcing agency. <p>(Support documentation required at application submittal)</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
Enhanced Durability and Reduced Maintenance			
<p>4.406.1 Rodent proofing. Annular spaces around pipes, electric cables, conduits, or other openings in plates at exterior walls shall be protected against the passage of rodents by closing such openings with cement mortar, concrete masonry or similar method acceptable to the enforcing agency.</p>	<input checked="" type="checkbox"/>		<p><i>Special Inspector</i></p> <input type="checkbox"/>
Water Resistance and Moisture Management			
<p>A4.407.1 Drainage around foundation. Install foundation and landscape drains which discharge to a dry well, sump, bioswale or other approved location.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.407.2 Roof drainage. Install gutter and downspout systems to route water at least 5 feet away from the foundation or connect to landscape drains which discharge to a dry well, sump, bioswale, rainwater capture system or other approved on-site location.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.407.3 Flashing details. Provide flashing details on the building plans and comply with accepted industry standards or manufacturers instructions.</p>		<input type="checkbox"/>	<p>City Plan Check staff</p> <input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.407.4 Material protection. Protect building materials delivered to the construction site from rain and other sources of moisture.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
<p>A4.407.6 Door protection. Exterior doors to the dwelling are protected by min. 4 ft. to prevent water intrusion.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>
<p><i>Description of proposed measures:</i></p>	<p><i>Sheet: Detail:</i></p>		
<p>A4.407.7 Roof overhangs. A permanent overhang or awning at least 2 feet in depth is provided at all exterior walls.</p>		<input type="checkbox"/>	<p><i>Special Inspector</i></p> <input type="checkbox"/>

Construction Waste Reduction, Disposal and Recycling			
<p>4.408.1 Construction waste management. Recycle and/or salvage for reuse nonhazardous construction waste in accordance with Section 4.408.2 or 4.408.3</p> <p>Support documentation required at application submittal.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Excavated soil and land-clearing debris 2. Alternate waste reduction methods 3. Isolated job sites <p>4.408.2 Construction waste management plan. Submit a construction waste management plan that:</p> <ol style="list-style-type: none"> 1. Identifies the construction waste materials to be diverted from disposal by efficient usage, recycling, reuse on the project or salvage for future use or sale. 2. Determines if construction waste materials will be sorted on-site or bulk mixed. 3. Identifies diversion facilities where construction waste material collected will be taken. 4. Identifies construction methods employed to reduce the amount of construction and demolition waste generated. 5. Specifies that the amount of construction waste materials diverted shall be calculated by weight or volume, but not by both. <p>4.408.3 Waste management company. Utilize a waste management company that can provide verifiable documentation that the percentage of construction waste material diverted from the landfill complies with A4.408.1 Tier 1(see below).</p> <p>Note: The owner or contractor shall make the determination if the construction waste material will be diverted by a waste management company.</p>	<p style="text-align: center;"><input checked="" type="checkbox"/></p> <p style="text-align: center;">or</p> <p style="text-align: center;"><input checked="" type="checkbox"/></p>		<p style="text-align: center;">City Plan Check Staff</p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;">or</p> <p style="text-align: center;"><input type="checkbox"/></p>
<p>A4.408.1 Enhanced construction waste reduction. At least 65% of nonhazardous construction and demolition debris generated at the site is diverted to recycle or salvage. (Tier 1)</p> <p>A4.408.1.1 Documentation. Documentation shall be provided to the enforcing agency which demonstrates compliance with this section. Documentation shall be compliance with Section 4.408.5</p>	<p style="text-align: center;"><input checked="" type="checkbox"/></p>		<p style="text-align: center;"><i>Special Inspector</i></p> <p style="text-align: center;"><input type="checkbox"/></p>

Building Maintenance and Operation			
<p>4.410.1 Operation and maintenance manual. At the time of final inspection, a manual which includes all of the following shall be placed in the building:</p> <ol style="list-style-type: none"> 1. Directions to the owner or occupant that the manual shall remain with the building throughout the life cycle of the structure. 2. Operation and maintenance instructions for; equipment and appliances, roof and yard drainage, space conditioning systems, landscape irrigation systems, and water reuse systems. 3. Information on local recycle programs and locations. 4. Public transportation and/or carpool options available in the area. 5. Educational material on the positive impacts of interior relative humidity between 30-60%. 6. Information about water-conserving landscape and irrigation design and controllers which conserve water. 7. Instructions for maintaining gutters and downspouts and importance of diverting water at least 5ft. away from the foundation. 8. Information on required routine maintenance measures including caulking, painting, grading around the house, etc. 9. Information about state solar energy and incentive programs available. 10. A copy of all special inspection verifications required by the enforcing agency or this code. 	☒		Special Inspector <input type="checkbox"/>
Innovative Concepts and Local Environmental Conditions			
<p>A4.411.1 Innovative concepts and local environmental conditions. Items in this section are necessary to address innovative concepts or local environmental conditions.</p>			Chief Building Official
Item:		<input type="checkbox"/>	<input type="checkbox"/>
A4.5 ENVIRONMENTAL QUALITY		<i>All checked items are required</i>	<i>Select at least one (1) elective measure from A4.5</i> <i>Select all measures verified in the completed project</i>
Fireplaces			
<p>4.503.1 Fireplaces. Install only a direct-vent or sealed-combustion gas fireplace. Wood-pellet stove shall comply with EPA Phase II or local ordinances. (Support documentation may be required at application submittal)</p>	☒		Special Inspector <input type="checkbox"/>
Pollutant Control			*All by Special Inspector
<p>4.504.1 Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation, during storage on the site and until final startup of the HVAC equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheetmetal or other methods acceptable to the enforcing agency to reduce the amount of water, dust and debris, which may enter the system.</p>	☒		* <input type="checkbox"/>

Interior Moisture Control			
<p>4.505.2 Concrete slab foundations. Concrete slab foundations required to have a vapor retarder by the California Building Code, Chapter 19, or the California Residential Code, Chapter 5, shall comply with this section.</p> <p>4.505.2.1 Capillary break. A capillary break shall be installed in compliance with at least one of the following:</p> <ol style="list-style-type: none"> 1. A 4" thick base of 1/2" or larger clean aggregate w/vapor barrier in direct contact with concrete 2. Other methods approved by the enforcing agency. 3. A slab design specified by a licensed designed professional. 	☒		City Building Inspector <input type="checkbox"/>
<i>Description of proposed measures:</i>		<i>Sheet:</i>	<i>Detail:</i>
<p>4.505.3 Moisture content of building materials. Building materials with visible signs of water damage shall not be installed. Wall and floor framing shall not be enclosed when the framing members exceed 19% moisture content. Moisture content shall be verified in compliance with the following:</p> <ol style="list-style-type: none"> 1. By a probe-type or contact-type moisture meter or other equivalent methods approved by the enforcing agency. 2. Readings shall be taken at a point 2 ft. to 4 ft. from the grade stamped end of each piece to be verified. 3. Minimum 3 random reading shall be performed on wall and floor framing with documentation provided to enforcing agency. 	☒		Special Inspector <input type="checkbox"/>
Indoor Air Quality and Exhaust			
<p>4.506.1 Bathroom exhaust fans. Each bathroom shall be mechanically ventilated and shall comply with the following:</p> <ol style="list-style-type: none"> 1. Fans shall be ENERGY STAR compliant and ducted to terminate outside the buildings. 2. Unless functioning as a whole house ventilation system, fans must be humidity controlled. Controls must be capable of adjustment between 50-80% humidity range. Humidity control may be a separate component to the exhaust fan and is not required to be integral or built-in. <p>Note: A bathroom is a room which contains a bathtub, shower, or combination shower/tub.</p>	☒		Special Inspector <input type="checkbox"/>
<p>A4.506.1 Filters. Return air filters with a value greater than MERV 6 shall be installed on HVAC systems. Pressure drop across the filter shall not exceed 0.1 inches water column.</p>		<input type="checkbox"/>	Special Inspector <input type="checkbox"/>
<p>A4.506.2 Construction filter. Provide filters on return air openings rated at MERV 6 or higher during construction.</p>		<input type="checkbox"/>	Special Inspector <input type="checkbox"/>
<p>A4.506.3 Direct-vent appliances. Direct-vent heating and cooling equipment shall be utilized if the equipment will be located in the conditioned space or install the space heating and water heating equipment in an isolated mechanical room.</p>		<input type="checkbox"/>	Special Inspector <input type="checkbox"/>
Environmental Comfort			

<p>4.507.2. Heating and air-conditioning system design. Heating and air-conditioning systems shall be sized, designed and have their equipment selected using the following methods: (Support documentation required at application submittal)</p> <ol style="list-style-type: none"> 1. Establish heat loss and heat gain values according to ANSI/ACCA Manual J-2004, ASHRAE handbooks or other equivalent methods. 2. Size duct systems according to ANSI/ACCA 1 Manual D – 2009, ASHRAE handbooks or other equivalent methods. 3. Select heating and cooling equipment according to ANSI/ACCA 3 Manual S – 2004 or other equivalent methods. <p>Exception: Use of alternate design temperatures necessary to ensure the systems function are acceptable.</p>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>		<p>City Plan Check staff</p> <p><input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/></p>
<p><i>Description of proposed measures:</i></p>	<p style="text-align: right;"><i>Sheet: Detail:</i></p>		
<p>Innovative Concepts and Local Environmental Conditions</p>			
<p>A4.509.1 Items in this section are necessary to address innovative concepts or local environmental conditions.</p>			<p>Chief Building Official</p>
<p>Item:</p>		<p><input type="checkbox"/></p>	<p><input type="checkbox"/></p>
<p>INSTALLER AND SPECIAL INSPECTOR QUALIFICATIONS</p>			<p><i>Select all measures verified in the completed project</i></p>
<p>Qualifications</p>			
<p>702.1 Installer training. HVAC system installers are trained and certified in the proper installation of HVAC systems.</p>	<p><input checked="" type="checkbox"/></p>		<p style="color: green;">Special Inspector</p> <p><input type="checkbox"/></p>
<p>702.2 Special inspection. The green building special inspector for this project is listed by the local jurisdiction as an Approved CALGreen Special Inspector and is qualified and able to demonstrate competence in the discipline they inspect and verify.</p>	<p><input checked="" type="checkbox"/></p>		<p>City Plan Check staff</p> <p><input type="checkbox"/></p>

CALGreen Building Acknowledgments

Project Address: _____

Project Description: _____

Section 1 - Design Verification

Complete all lines of Section 1- "Design Verification" and submit the completed checklist (Columns 1 and 2) with the plans and building permit application to the Building Division.

The owner, design professional and the local jurisdiction Approved CALGreen Special Inspector have reviewed the plans and certify that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2013 California Green Building Standards Code as amended by the local jurisdiction.

Owner's Signature

Date

Owner Name *(Please Print)*

Design Professional's Signature

Date

Design Professional's Name *(Please Print)*

Signature of Listed CAL Green Building Special Inspector

Date

Listed CALGreen Special Inspector's Name *(Please Print)*

Phone

CALGreen Special Inspector's E-mail Address

Section 2 - Implementation Verification

Complete, sign and submit the completed checklist, including Column 3, together with all original signatures on Section 2 – "Implementation Verification" to the Building Department prior to Building Division final inspection.

I have inspected the work have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with this Green Building Checklist and in accordance with the requirements set forth in the 2013 California Green Building Standards Code as amended by the local jurisdiction.

Listed Approved CALGreen Special Inspector Signature

Date

Green Building Special Inspector's Name *(Please Print)*

Phone *(if different than above)*

Green Building Special Inspector's E-mail Address *(if different than above)*