BUILDING DEPARTMENT INFORMATIONAL HANDOUT

2016 CALGreen Checklist for NONRESIDENTIAL ADDITIONS and ALTERATIONS

SCOPE: The provisions of this checklist apply to nonresidential <u>building additions of 1800 square feet or greater</u>, and/or <u>building alterations or repairs of 50% or greater</u> and only applies to the portions of the building being added to or altered within the scope of the permitted work. The provisions of this checklist also apply to all tenant improvement projects meeting the criteria listed above.

Newly constructed nonresidential buildings must use the CALGreen checklist for New Nonresidential Buildings.

(This checklist i	s based on 2016 CALGreen and has been revised to include City of Sebastopol requirements.)
Project Address:	
Project Name:	
Project Description:	

Instructions:

- 1. The Owner or the Owner's agent may employ a qualified CALGreen Special Inspector to perform CALGreen Special Inspector services and to verify and assure the Owner and the Building Department that all required work described herein is properly planned and implemented in the project.
- 2. The CALGreen Special Inspector shall not be the design professional or contractor for the project and shall not have a financial interest in the project for which services are being provided except for the cost of providing said services.
- 3. The CALGreen Special Inspector, in collaboration with the owner and the design professional shall review and incorporate all applicable provisions of Columns 1 and 2 of this checklist into the project, sign and date the Design Verification section at the end of this checklist and have the checklist printed on the approved plans for the project. The CALGreen Special Inspector must indicate in Column 2 of the checklist all applicable measures which must be met and incorporated into the project.
- 4. Prior to final inspection by the Building Department, CALGreen Special Inspector shall complete **Column 3** and sign and date **the Implementation Verification** section at the end of this checklist.

[NOTE: The Tier 1 and Tier 2 provisions of CALGreen do not apply to Addition and Alteration projects.]

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the Sebastopol Municipal Code for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
MANDATORY MEASURES FOR ADDITIONS AND ALTERATIONS TO EXISTING NONRESIDENTIAL BUILDINGS	All listed measures are mandatory unless Not Applicable "N/A"	Select all measures <u>verified</u> in the completed project.
PLANNING & DESIGN (DIVISION 5.1)		
5.106.1 Storm water pollution prevention. Additions that disturb less than one acre of land shall prevent the pollution of stormwater runoff from construction activities in accordance with Sebastopol Municipal Code Chapter 15.78 (Stormwater LID Manual).	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.106.4 Bicycle parking. Comply with Sections 5.106.4.1.1 and 5.106.4.1.2. 5.106.4.1.1 Short-term bicycle parking. If the project is anticipated to generate visitor traffic and adds 10 or more vehicular parking spaces, provide permanently anchored bicycle racks within 200 feet of the visitors' entrance, readily visible to passers-by, for 5% of the additional visitor motorized vehicle parking capacity, with a minimum of one two-bike	Mandatory or ☐ N/A	
capacity rack. 5.106.4.1.2 Long-term bicycle parking. For buildings adding 10 or more tenant vehicular parking spaces, provide secure bicycle parking for 5% of the additional vehicular parking spaces added, with a minimum of one space.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
 5.106.5.2 Designated parking for clean air vehicles. For projects that add 10 or more vehicular parking spaces, provide designated parking for any combination of low-emitting, fuel-efficient, and carpool/van pool vehicles as shown in Table 5.106.5.2 based on the number of additional spaces. 5. 106.5.2.1 Parking stall marking. If applicable above, paint the following characters such that the lower edge of the last word aligns with the end of the stall striping and is visible beneath a parked vehicle: "CLEAN AIR /VANPOOL / EV " 	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	

 $^{^{\}rm 1}$ Modified to conform with Chapter 15.78 of the Sebastopol Municipal Code

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.106.10 Grading and Paving. For <u>projects altering the drainage path</u> , Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include those shown below:	Mandatory or ☐ N/A	
1. Swales.		
Water collection and disposal systems.		
3. French drains		
4. Water retention gardens		
Other water measures which keep surface water away from buildings and aid in groundwater recharge.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
ENERGY EFFICIENCY (Division 5.2)		
5.201.1 Scope. Building shall meet or exceed the requirements of the California Building Energy Efficiency Standards.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
WATER EFFICIENCY AND CONSERVATION (Division 5.3)		
5.303 Indoor Water Use.		
5.303.1 Meters. Separate submeters or metering device shall be installed for the uses described in Sections 5.303.1.1 and 5.303.1.2 below.		
5.303.1.1 Additions to existing buildings in excess of 50,000 square feet. Separate submeters shall be installed as follows:	Mandatory or	
 For each individual leased, rented, or other tenant space within the building projected to consume more than 100 gal/day. 	□ N/A	
Where separate submeters for individual building tenants are unfeasible, for water supplied to the following subsystems:		
a. Makeup water for cooling towers where flow through is greater than 500 gpm.		
b. Makeup water for evaporative coolers greater than 6 gpm.		
c. Steam and hot-water boilers with energy input more than 500,000 Btu/h (147 kW)		
5.303.1.2 Excess consumption. A separate sub-meter or metering device shall be provided for any tenant within a new building or addition that is projected to consume more than 1,000 gal/day.		
5.303.3 Water conserving plumbing fixtures and fittings. Plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) shall comply with the following:	Mandatory or	
5.303.3.1 Water closets. The effective flush volume of all water closets shall not exceed 1.28 gallons per flush. Tank-type water closets shall be certified to the performance criteria of the U.S. EPA Water Sense Specification for Tank-Type Toilets.	□ N/A	
Note: The effective flush volume of dual flush toilets is defined as the composite, average flush volume of two reduced flushes and one full flush.		
5.303.3.2.1 Wall-Mounted Urinals. The effective flush volume of urinals shall not exceed 0.125 gallons per flush.		
5.303.3.2.2 Floor-Mounted Urinals. The effective flush volume of urinals shall not exceed 0.5 gallons per flush.		Ц
5.303.3.3 Showerheads.		
5.303.3.3.1 Single showerhead. Showerheads shall have a maximum flow rate of not more than 2.0 gallons per minute at 80 psi. Showerheads shall be certified to the performance criteria of the U.S. EPA Water Sense Specification for Showerheads.		
5.303.3.3.2 Multiple showerheads serving one shower . When a shower is served by more than one showerhead, the combined flow rate of all showerheads and/or other shower outlets controlled by a single valve shall not exceed 2.0 gallons per minute at 80 psi, or the shower shall be designed to allow only one shower outlet to be in operation at a time.		
Note: A hand-held shower shall be considered a showerhead.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.303.3.4 Faucets and fountains. Faucets and fountains shall comply with all of the following:	Mandatory or	(all applicable
5.303.3.4.1 Nonresidential lavatory faucets. Lavatory faucets shall have a maximum flow rate of not more than 0.5 gallons per minute at 60 psi.	□ N/A	measures)
5.303.3.4.3 Kitchen faucets. Kitchen faucets shall have a maximum flow rate of not more than 1.8 gallons per minute at 60 psi. Kitchen faucets may temporarily increase the flow above the maximum rate, but not to exceed 2.2 gallons per minute at 60 psi, and must default to a maximum flow rate of 1.8 gallons per minute at 60 psi.		
5.303.3.4.3 Wash fountains. Wash fountains shall have a maximum flow rate of not more than 1.8 gallons per minute/20 [rim space (inches) at 60 psi],		
5.303.3.4.4 Metering faucets. Metering faucets shall not deliver more than 0.20 gallons per cycle.		
5.303.3.4.5 Metering faucets for wash fountains. Metering faucets for wash fountains shall have a maximum flow rate of not more than 0.20 gallons per cycle/20 [rim space (inches) at 60. psi].		
Note: Where complying faucets are unavailable, aerators or other means may be used to achieve reduction.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.303.4 Commercial kitchen equipment.	Mandatory	
5.303.4.1 Food waste disposers. Disposers shall either modulate the use of water to no more than 1 gpm when the disposer is not in use (not actively grinding food waste/no-load) or shall automatically shut off after no more than 10 minutes of inactivity. Disposers shall use no more than 8 gpm of water.	or N/A	
5.303.5 Areas of additions or alteration. For those occupancies within the authority of the California Building Standards Commission as specified in Section 103, the provisions of Section 5.303.3 and 5.303.4 shall apply to new fixtures in additions or areas of alterations to the building.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.303.6 Standards for plumbing fixtures and fittings. Plumbing fixtures and fittings shall be installed in accordance with the California Plumbing Code, and shall meet the applicable standards referenced in Table 1701.1 of the California Plumbing Code and in Chapter 6 of this code.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.304.1 Scope. The provisions of Section 5.304 Outdoor Water Use reference the mandatory Model Water Efficiency Landscape Ordinance (MWELO) contained within Chapter 2.7, Division 2, Title 23, <i>California Code of Regulations</i> and with Chapter 15.36 of the Sebastopol Municipal Code (Water Efficient Landscaping).	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.304.2. Outdoor potable water use. For building additions or alterations requiring <u>upgraded</u> water service for landscaped areas of at least 1,000 square feet but not more than 5,000 square feet, separate submeters or metering devices shall be installed for outdoor potable water use.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.304.3 Outdoor water use in rehabilitated landscape projects equal to or greater than 2,500 square feet. Rehabilitated landscape projects with an aggregate landscape area equal to or greater than 2,500 square feet requiring a building or landscape permit, plan check, or design review shall comply with Section 5.304.2, Item 1 or 2.	Mandatory or ☐ N/A	
5.304.4 Outdoor water use in landscape areas of 2,500 square feet or less . Any project with an aggregate landscape area of 2,500 square feet or less may comply with the performance requirements of .MWELO or conform to the prescriptive compliance measures contained in MWELO's Appendix D.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.304.5 Graywater or rainwater use in landscape areas. For projects using treated or untreated graywater or rainwater captured on site, any lot or parcel within the project that has less than 2,500 square feet of landscape and meets the lot or parcel's landscape water requirement (Estimated Total Water Use) entirely with treated or untreated graywater or through stored rainwater captured on site is subject only to Appendix D Section (5).	Mandatory or \[\] N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

Column 1 Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
MATERIAL CONSERVATION AND RESOURCE EFFICIENCY (Division 5.4)		
5.407 Weather Resistance and Moisture Management.		
5.407.1 Weather protection. Provide a weather-resistant exterior wall and foundation envelope as required by California Building Code Section 1403.2 and California Energy Code Section 150, manufacturer's installation instructions, or local ordinance, whichever is more stringent.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	
 5.407.2 Moisture control. When adding or altering irrigation sprinklers or entries and openings to a building, employ moisture control measures by the following methods; 5.407.2.1 Sprinklers. Prevent irrigation spray on structures. 5.407.2.2 Entries and openings. Design exterior entries and/or openings subject to foot traffic or wind-driven rain to prevent water intrusion into buildings. 	Mandatory or N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	

Column 1 Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.408 Construction Waste Reduction, Disposal and Recycling.		
5.408.1 Construction waste management. Recycle and/or salvage for reuse a minimum of 65% of the nonhazardous construction waste in accordance with Section 5.408.1.1 or 5.408.1.2; or 5.408.1.3; or meet a local construction and demolition waste management ordinance, whichever is more stringent.	Mandatory or \[\] N/A	
5.408.1.1 Construction waste management plan. Submit a construction waste management plan that complies with Items 1 through 4 of Section 5.408.1.1. (Support documentation required prior to permit issuance)	Mandatory	
5.408.1.2 Waste management company. Utilize a waste management company that can provide verifiable documentation that the percentage of construction waste material diverted from the landfill complies with this section. (Support documentation required prior to permit issuance)	Mandatory or \[\] N/A	
Exceptions to Sections 5.408.1.1 and 5.408.1.2:		
Excavated soil and land-clearing debris		
Alternate waste reduction methods developed by working with local agencies if diversion or recycle facilities capable of compliance with this item do not exist.		
Demolition waste meeting local ordinance or calculated in consideration of local recycling facilities and markets.		
5.408.1.3 Waste stream reduction alternative. The combined weight of new construction disposal that does not exceed two pounds per square foot of building area may be deemed to meet the 50 percent minimum requirement as approved by the enforcing agency.		
5.408.1.4 Documentation. Provide documentation of the waste management plan that meets the requirements listed in Sections 5.408.1.1 through 5.408.1.3, and the plan is accessible to the enforcement authority. (Support documentation required prior to permit issuance)	Mandatory	
5.408.2 Universal Waste. [A] Additions and alterations to a building or tenant space shall require verification that Universal Waste items such as fluorescent lamps and ballast and mercury containing thermostats as well as other California prohibited Universal Waste materials are disposed of properly and are diverted from landfills. A list of prohibited Universal Waste materials shall be included in the construction documents.	Mandatory or ☐ N/A	
Note: Refer to the Universal Waste Rule link at: http://www.dtsc.ca.gov/LawsRegsPolicies/Regs/upload/OEARA REGS UWR FinalText.pdf		_
5.408.3 Excavated soil and land clearing debris. 100% of trees, stumps, rocks and associated vegetation and soils resulting primarily from land clearing shall be reused or recycled.	Mandatory or ☐ N/A	
Exception: Reuse, either on-or off-site, of vegetation or soil contaminated by disease or pest infestation.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.410 Building Maintenance and Operation.		
5.410.1 Recycling by occupants. Provide readily accessible areas that serve the entire building and are identified for the depositing, storage, and collection of non-hazardous materials for recycling.	Mandatory	
5.410.1.1 Additions. All <u>additions</u> conducted within a 12-month period under single or multiple permits, resulting in an increase of 30 percent or more in floor area, shall provide recycling areas on site. Exception: Additions within a tenant space resulting in less than a 30-percent increase in the tenant space floor area.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.410.4 Testing and adjusting. Testing and adjusting of systems shall be required for buildings less than 10,000 square feet. Applies to new systems serving additions or alterations. Applies to new systems serving additions or alterations.	Mandatory or \[\sum N/A	
5.410.4.2 Systems. Develop a written plan of procedures for testing and adjusting systems. Systems to be included for testing and adjusting shall include, as applicable to the project, the following: HVAC systems and controls. Indoor and outdoor lighting and controls. Water heating systems. Renewable energy systems. Landscape irrigation systems. Water reuse systems.	Mandatory or N/A	
5.410.4.3 Procedures . Perform testing and adjusting procedures in accordance with applicable standards on each system as determined by the enforcing agency.	Mandatory or ☐ N/A	
5.410.4.3.1 HV AC balancing. In addition to testing and adjusting, before a new space-conditioning system serving a building or space is operated for normal use, balance the system in accordance with the procedures defined by national standards listed in Section 5.410.4.3.1 or as approved by the enforcing agency.		
5.410.4.4 Reporting. After completion of testing, adjusting and balancing, provide a final report of testing signed by the individual responsible for performing these services.	Mandatory or ☐ N/A	
5.410.4.5 Operation and maintenance manual. Provide the building owner or representative with detailed operating and maintenance instructions and copies of guaranties/warranties for each added or altered system prior to final inspection.	Mandatory or ☐ N/A	
5.410.4.5.1 Inspections and reports. Include a copy of all inspection verifications and reports required by the enforcing agency.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	

Column 1 Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
ENVIRONMENTAL QUALITY (Division 5.5)		
5.503 Fireplaces. 5.503.1 General (Fireplaces). Install only a direct-vent sealed-combustion gas or sealed wood-burning fireplace, or a sealed woodstove meeting the requirements of Sebastopol Municipal Code Chapter 15.70 (Wood-Burning Appliances).	Mandatory or □ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
POLLUTANT CONTROL		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
 5.504 Pollutant Control. 5.504.1.3 Temporary ventilation. If the HV AC system serving the added or altered area(s) is used during construction, use return air filters with a MERV of 8, based on ASHRAE 52.2-1999, or an average efficiency of 30% based on ASHRAE 52.1-1992. Replace all filters of the HV AC system serving the added or altered area(s) immediately prior to occupancy. 	Mandatory or □ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.504.3 Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation and during storage on the construction site and until final startup of the heating, cooling and ventilating equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheet metal or other methods acceptable to the enforcing agency to reduce the amount of dust, water and debris which may enter the system.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.504.4 Finish material pollutant control. Newly installed finish materials shall comply with Sections 5.504.4.1 through 5.504.4.6.		
5.504.4.1 Adhesives, sealants, caulks. Newly installed adhesives and sealants used on the project shall meet the requirements of the following standards.	Mandatory or	
 Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, and caulks shall comply with local or regional air pollution control or air quality management district rules where applicable, or SCAQMD Rule 1168 VOC limits, as shown in Tables 5.504.4.1 and 5.504.4.2. in Division 5 	□ N/A	Ш
2. Aerosol adhesives, and smaller unit sizes of adhesives, and sealant or caulking compounds (in units of product, less packaging, which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards and other requirements, including prohibitions on use of certain toxic compounds, of California Code of Regulations, Title 17, commencing with Section 94507.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.504.4.3 Paints and coatings. Newly installed architectural paints and coatings shall comply with Table 5.504.4.3 in Division 5.5.	Mandatory or	
5.504.4.3.1 Aerosol Paints and Coatings . Newly installed aerosol paints and coatings shall meet the Product-Weighted MIR Limits for ROC in section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances (CCR, Title 17, Section 94520 et seq).	□ N/A	
5.504.4.3.2 Verification. Verification of compliance with this section shall be provided when requested by the enforcing agency.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.504.4.4 Carpet systems. All <u>newly installed carpet</u> in the building interior shall meet the testing and product requirements of one of the standards listed in Section 5.504.4.4.	Mandatory or	
5.504.4.4.1 Carpet cushion. All <u>newly installed carpet cushion</u> in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program.	□ N/A	
5.504.4.4.2 Carpet adhesive . All <u>newly installed carpet adhesive</u> shall meet the requirements of Table 5.504.4.1 in Division 5.5.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.504.4.5 Composite wood products. Newly installed hardwood plywood, particleboard, and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.5.	Mandatory or ☐ N/A	
5.504.4.5.2 Documentation. Verification of compliance with this section shall be provided when requested by the enforcing agency. Documentation shall include at least one of the following as applicable.	Mandatory	
Product certifications and specifications.		
2. Chain of custody certifications.		
Product labeled and invoiced as meeting the Composite Wood Products regulation (see CCR, Title 17, Section 93120, et seq.)		
 Exterior grade products marked as meeting the PS-1 or PS-2 standards of the Engineered Wood Association, the Australian AS/NZS 2269 or European 636 3S standards. 		
Other methods acceptable to the enforcing agency.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.504.4.6 Resilient flooring systems. For 80 percent of floor area receiving resilient flooring, install resilient flooring that meets one of the following:	Mandatory or	
☐ 1. Certified under the Resilient Floor Covering Institute (RFCI) FloorScore program;	□ N/A	
2. Compliant with the VOC-emission limits and testing requirements specified in the California Department of Public Health's 2010 Standard Method for the Testing and Evaluation Chambers, Version 1.1, February 2010;		
3. Compliant with the Collaborative for High Performance Schools California (CA-CHPS) Criteria Interpretation for EQ 7.0 and 7.1 (formerly EQ. 2.2) dated July 2012 and listed in the CHPS High Performance Product Database; or		
 4. Products certified under UL GREENGUARD Gold (formerly the Greenguard Children's & Schools Program). 		
5.504.4.6.1 Verification of compliance . Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits. (Support documentation required prior to final inspection approval)		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

Column 1 Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.504.5.3 Filters. In mechanically ventilated spaces serving additions or altered areas of buildings, provide regularly occupied areas of the building with air filtration media for outside and return air that provides at least a MERV of 8. MERV 8 filters shall be installed prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual. Exceptions:	Mandatory or ☐ N/A	
 An ASHRAE 10-percent to 15-percent efficiency filter shall be permitted for an HVAC unit meeting the California Energy Code having 60,000 Btu/h or less capacity per fan coil, if the energy use of the air delivery system is 0.4 W/cfm or less at design air flow. Existing mechanical equipment. 		
5.504.5.3.1 Labeling. Installed filters shall be clearly labeled by the manufacturer indicating the MERV rating.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.504.7 Environmental tobacco smoke (ETS) control. Where outdoor areas are provided for smoking, prohibit smoking (by posting no smoking signage) within 25 feet of building entries, outdoor air intakes and operable windows and within the building as already prohibited by other laws or regulations; or as enforced by ordinances, regulations, or policies of any city or county, whichever are more stringent. See Sonoma Municipal Code Chapter 7.24 (Smoking Regulations).	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	
 5.505 Indoor Moisture Control. 5.505.1 Indoor moisture control. Additions or altered spaces within buildings shall meet or exceed the provisions of California Building Code, CCR, Title 24, Part 2, Sections 1203 (Ventilation) and Chapter 14 (Exterior Walls). For additional measures not applicable to low-rise residential occupancies, see Section 5.407.2. 	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.506 Indoor Air Quality. 5.506.1 Outside air delivery. Where newly installed, mechanically or naturally ventilated	Mandatory	
spaces in additions or altered spaces within buildings, shall meet the minimum requirements of Section 120.1 of the California Energy Code and Chapter 4 of CCR, Title 8, or the applicable local code, whichever is more stringent.	or □ N/A	_
5.506.2 Carbon dioxide (CO₂) monitoring . For <u>additions equipped with demand control ventilation</u> , CO ₂ sensors and ventilation controls shall be specified and installed in accordance with the requirements of the latest edition of the California Energy Code, Section 120(c)(4).	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

<u>Column 1</u> Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.507 Environmental Comfort.		
5.507.4 Acoustical control. Employ building assemblies and components with STC values determined in accordance with ASTM E 90 and ASTM E 413 or OITC determined in accordance with ASTM E 1332, using either the prescriptive or performance method in Section 5.07.4.1 or 5.507.4.2. (Support documentation required prior to permit issuance)	<u>Choose</u> either Prescriptive or Performance method	<u>Verify</u> either Prescriptive or Performance method
5.507.4.1 Exterior noise transmission, <u>Prescriptive Method</u> . Wall and floor-ceiling assemblies exposed to the noise source making up the building envelope shall have exterior wall and roof-ceiling assemblies meeting a composite STC rating of at least 50 or a composite OITC rating of no less than 40 with exterior windows of a minimum STC of 40 or OITC of 30 in the locations described in Items 1 and 2.	☐ Prescriptive	
5.507.4.1.1 Noise exposure where noise contours are not readily available. Buildings exposed to a noise level of 65 dB L _{eq} -1Hr during any hour of operation shall have exterior wall and roof-ceiling assemblies exposed to the noise source meeting a composite STC or rating of at least 45 (or OITC 35), with exterior windows of a minimum STC of 40 (or OITC 30).	or	or
or	OI .	OI .
5.507.4.2 Exterior noise transmission , <u>Performance Method</u> . For buildings located as defined in Sections 5.507.4.1 or 5.507.4.1.1, wall and roof-ceiling assemblies making up the building envelope shall be constructed to provide an interior noise environment attributable to exterior sources that does not exceed an hourly equivalent noise level (Leq-1Hr) of 50 dBA in occupied areas during any hour of operation.	☐ Performance	
5.507.4.2.1 Site features. Exterior features such as sound walls or earth berms may be utilized as appropriate to the project to mitigate sound migration to the interior.		
5.507.4.2.2 Documentation of compliance. An acoustical analysis documenting complying interior sound levels shall be prepared by personnel approved by the architect or engineer of record.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	
5.507.4.3 Interior sound transmission. Newly installed wall and floor-ceiling assemblies separating tenant spaces and public places shall have an STC of at least 40.	Mandatory or \(\sqrt{N/A}	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	

Column 1 Feature or Measure	Column 2 Mandatory Requirements	Column 3 Mandatory Verification
All listed measures are required where applicable to those portions of the building being added to or altered within the scope of the permitted work.	All listed measures must be incorporated into the project unless it is not applicable to the permitted work.	Verification required by a third party listed CALGreen Special Inspector or City Staff
See Chapter 5 of the 2016 California Green Building Code and the <u>Sebastopol Municipal Code</u> for complete descriptions of features or measures listed here	Select and explain any measures not applicable below	Complete after implementation and prior to final inspection approval
5.508 Outdoor Air Quality.		
5.508.1 Ozone depletion and greenhouse gas reductions. New installations of HVAC, refrigeration, and fire suppression equipment shall comply with Sections 5.508.1.1 and 5.508.1.2 below.	Mandatory or ☐ N/A	
5.508.1.1 Chlorofluorocarbons (CFCs.). Install HVAC, refrigeration and fire suppression equipment that does not contain CFCs.		
5.508.1.2 Halons. Install HVAC, refrigeration and fire suppression equipment that do not contain Halons.		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	s not applicable (N/A):	
5.508.2 Supermarket refrigerant leak reduction. New commercial refrigeration systems shall comply with the provisions of this section when installed in retail food stores 8,000 square feet or more conditioned area, and that utilize either refrigerated display cases, or walk-in coolers or freezers connected to remote compressor units or condensing units. The leak reduction measures apply to refrigeration systems containing high-global-warming potential (high-GWP) refrigerants with a GWP of 150 or greater. New refrigeration systems include both new facilities and the replacement of existing refrigeration systems in existing facilities.	Mandatory or ☐ N/A	
Exception: Refrigeration systems containing low-global warming potential (low-GWP) refrigerant with a GWP value less than 150 are not subject to this section. Low-GWP refrigerants are nonozone-depleting refrigerants that include ammonia, carbon dioxide (CO ₂), and potentially other refrigerants.		
[NOTE: See all requirements for refrigerant piping, valves, refrigerated service cases, refrigerant receivers, pressure testing and system evacuation contained under section 5.508.2.]		
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why the measure is	not applicable (N/A):	

INSTALLER AND SPECIAL INSPECTOR QUALIFICATIONS	All checked items are required for the project	Select all measures verified in the completed project
Qualifications (Chapter 7)		
702.1 HVAC system installers (if any) are trained and certified in the proper installation of HVAC systems.	Mandatory or ☐ N/A	
Indicate the plan sheet number where the above measure is noted on plans or provide explanation of why	the measure is not appli	cable (N/A):
702.2 The CALGreen Special Inspector for this project is qualified and able to demonstrate competence in the discipline they inspect and verify.	Mandatory	
Verifications		
703.1 Verification of compliance with CALGreen for Nonresidential Additions and Alterations may include construction documents, plans, specifications builder or installer certification, inspection reports, or other methods acceptable to the enforcing agency which show substantial conformance. Implementation verification shall be submitted to the Building Department after implementation of all required measures and prior to final inspection approval.	Mandatory	

Green Building Acknowledgments

Project Address:	
Project Description:	
Section 1 - Design Verification Complete all lines of Section 1- "Design Verification" and submit the completed checkl building permit application to the Building Department.	list (Columns 1 and 2) with the plans and
The owner, design professional <u>and</u> CALGreen special inspector have reviewed checked above are hereby incorporated into the project plans and will be implicated in the requirements set forth in the 2016 California Green Building Standard of the Sebastopol Municipal Code.	lemented into the project in accordance
Owner's Signature	Date
Owner Name (Please Print)	_
Design Professional's Signature	Date
Design Professional's Name (Please Print)	_
Signature of City Listed CALGreen Special Inspector	Date
City Listed CALGreen Special Inspector's Name (Please Print)	Phone
CALGreen Special Inspector's E-mail Address	CALGreen Certification No.
Section 2 - Implementation Verification Complete, sign and submit the completed checklist, including Column 3, together with "Implementation Verification" to the Building Department prior to Building Department I have inspected the work have received sufficient documentation to verify an was constructed in accordance with this Green Building Checklist and in accordance the 2016 California Green Building Standards Code as amended by Chapter	final inspection. d certify that the project identified above ordance with the requirements set forth in
City Listed CALGreen Special Inspector Signature	Date
CALGreen Special Inspector's Name (Please Print)	Phone (if different than above)
CALGreen Special Inspector's E-mail Address (if different than above)	CALGreen Certification No.